



Across-Line Starter

Bulletin 9101

Select Heater Coil from the table in accordance with the current rating of your motor.

Motor Amperes		Index No. of One Heater Coil 9102-	Ampere Rating Stamped on Heater Coil
Min.	Max.		
.75-	.83	H1A	.88
.84-	.91	H2A	.96
.92-	1.03	H3A	1.1
1.04-	1.11	H4A	1.2
1.12-	1.23	H5A	1.3
1.24-	1.36	H6A	1.4
1.37-	1.47	H7A	1.6
1.48-	1.63	H8A	1.7
1.64-	1.83	H9A	1.9
1.84-	2.01	H10A	2.1
2.02-	2.25	H11A	2.4
2.26-	2.43	H12A	2.6
2.44-	2.68	H13A	2.8
2.69-	2.96	H14A	3.1
2.97-	3.24	H15A	3.4
3.25-	3.66	H16A	3.8
3.67-	4.05	H17A	4.2
4.06-	4.50	H18A	4.7
4.51-	5.09	H19A	5.3
5.10-	5.42	H20A	5.7
5.43-	6.06	H21A	6.4
6.07-	6.65	H22A	7.0
6.66-	7.40	H23A	7.8
7.41-	8.28	H24A	8.7
8.29-	9.15	H25A	9.7
9.16-	10.0	H26A	10.5
10.1-	11.1	H27A	11.7
11.2-	12.3	H28A	12.9
12.4-	13.5	H29A	14.2
13.6-	14.8	H30A	15.6

Connection Diagrams

The diagrams are shown for various arrangements of conduit connections. Use the most suitable diagram and place connector where indicated. Be sure to remove connector when wiring per Fig. 3.




FIG. 1 BOTTOM WIRING




FIG. 2 TOP WIRING




FIG. 3 THRU WIRING

Description	Index No.
Enclosed Type	9101H60A
Open Type	9101H59A
Voltage	H. P. Rating
110-220 Single Phase	1/2 H. P.
115 D. C.	1/2 H. P.
230 D. C.	1/2 H. P.

CUTLER-HAMMER, Inc. Milwaukee, Wis.

Offices and Agents in Principal Cities

Pub. No. 4679, Sup. issue dated April 1935

Made in U. S. A.

May 1935